

Attestation

AgBB

On 23 August 2021, Eurofins Product Testing A/S received a sample of joint sealant with the product name:

HIT-FP 700-R

supplied by

Hilti Entwicklungsgesellschaft mbH


The emissions were tested according to AgBB (AgBB - Committee for Health-related Evaluation of Building Products). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 16017-1 (see the test report no. 392-2021-00413601_A_EN).

Evaluation of the emission test result according to AgBB:

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m³.
- The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m³.
- The sum of SVOC after 28 days was below the limit of 0.1 mg/m³.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was below the limit of 1.
- The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m³.
- Formaldehyde after 28 days was below the limit of 0.1 mg/m³.

The tested product complies with the requirements of AgBB including the LCI-values (June 2021) for use in the indoor environment.

22 October 2021



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry